सत्यमेव जयते

Government of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services

C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo No.: FSR/IND/WB/FES/20192020/51989 **Date : 15-07-2024**

From :
Divisional Fire Officer
Murshidabad Division,
West Bengal Fire & Emergency Services

To :
RUPALISHA GHOSH SARKAR
Surya Memorial Academy for Sri Sri Manjushri Welfare Trust, Kairipara,Ranasagar, Kapasdanga G.P, P.S-Murshidabad, West Bengal,742149

Sub : Renewal of Fire Safety Certificate of an existing construction of G+2 storied building under group Educational at the premises mark Name: Surya Memorial Academy for Sri Sri Manjushri Welfare Trust, Kairipara,Ranasagar, Kapasdanga G.P, P.S-Murshidabad, Dist-Murshidabad, West Bengal,742149.

Memo No.: FSR/IND/WB/FES/20192020/51989

This is in reference to your AIN 211912406300001188 dated 03-Jul-2024 regarding Renewal of Fire Safety Certificate of an existing construction of G+2 storied building under group Educational at the premises mark Name: Surya Memorial Academy for Sri Sri Manjushri Welfare Trust, Kairipara,Ranasagar, Kapasdanga G.P, P.S-Murshidabad, Dist-Murshidabad, West Bengal,742149..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1.Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
2.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001188

be strictly Maintained.
3.Fire Notice for fire fighting and evacuation from the building shall be prepared and be displayed at vulnerable places of the building.
4.Floor numbers and directional sign of escape routs shall be displayed prominently.
5.The employees and security staff shall be conversant with installed fire fighting equipment's of the building and to operate in the event of Fire & Testing.
6.Applicant should apply for RFSR for the extension part of the building within six months.
7.Arrangement shall be made for regular checking, testing and proper maintenance of all the fire safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
8.Periodical flashing of water from the Hydrants Pipe line shall be made to maintain the efficient working performance of above mentioned system.
9.Mock fire practice and evacuation drill shall be performed periodically with participation of all occupants of the building.
10.Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
11.If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
13.Switch Gear room shall be protected with CO2 or D.C.P. Fire extinguisher conforming I. S. Specification.
14.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
15.This Renewal of Fire Safety Certificate is valid for three years with effect from the date of issue of this letter.
N.B: Any deviation and changes in the building in respect of the approved plan drawing, without obtaining prior permission from this office, this RFSC will be treated as cancelled.

Valid Upto : 14-Jul-2027

Memo No.: FSR/IND/WB/FES/20192020/51989

Signature Not Verified

Digitally Signed.
Name: SUBRATA GUHA
Date: 15-Jul-2024 12:24:54
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001188